

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0078:189 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Model 5808C battery operated with built-in wireless transmitter, photoelectric type smoke detector. Unit also can transmit a radio frequency (RF) alarm signal to listee's separately listed fire alarm control units. Unit also has a supplement integral heat sensor. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: Two 3 VDC lithium batteries: Duracell DL123A, Sanyo CR123A, Panasonic CR123A or Ademco 466.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as radio frequency type (RF), photoelectric smoke detector for use with separately listed fire alarm control units.

10-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager